

Laboratory approved by the Ministry for the Interior
JO of February 10, 2007OFFICIAL REPORT OF CLASSIFICATION OF FIRE PERFORMANCE
Of A MATERIAL ENVISAGED IN ARTICLE 5
DECREE OF November 21, 2002N° **CM - 22 - P - 040**

et 1 annexe de 4 pages.

Page 1

Valid 5 years as from mardi 3 mai 2022

Material presents by : **CAPOVERDE TBR**2871 avenue de l'Europe
69140 RILLIEUX LA PAPETrade mark: **CAPOTOILE XGL NV**

Summary description

Kind of coating fabric Tissage polyester recyclé avec enductions acryliques et traitement ignifugé

Composition support : 100% polyester recyclé ; enduction : acrylique

Mass per unit area 260 g/m² ; épaisseur : 0,27 mm (donnée laboratoire FCBA)

Color blanc

Kind of Fire retardant enductions acryliques avec traitement ignifuge

Nature of the test : Electrical burner test
Flame persistence test
Dripping test
Artificial ageing in water soakingClassification : **M1**

Observations : /

Durability of the classification (Article 5 de l'annexe 2) Not limited

Usual term Walls hung covering, sheers, curtains,...

Cleaning conditions Washable with water

Taking into account the criteria resulting from the tests annexed described in the test report N^{FE 22-0148-0739 & FE 22-0148-0744}

This official report attests only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certification of products within the meaning of the L.115-27 article of the code of the consumption and the law of June 3rd, 1994.

NOTE: The integral reproductions and by photocopy of this official report of classification are only authorized or the official report unit of classification and report of annexed test. These conclusions relate only to the resistance / reaction to fire performance of the element that is the subject of the present classification report. They do not prejudice, in any case, other performances related to its incorporation to a work "

"Not legally acceptable for any use under the pretence of the article AM 18 (Decree of March 6th, 2006) for upholstered seat"

Champs-sur-Marne, le mercredi 18 mai 2022

Technicien d'essais du Laboratoire Feu

Responsable Technique du laboratoire Feu
du Pôle Ameublement

Cyril FLEURIER



Clotilde ETIEMVRE

Only the french version remains valide

Institut technologique FCBA - Forêt, Cellulose, Bois - construction, Ameublement